

LEV System Reference

Systems Check for:	Status		Comments for Maintenance	Inspector/Operator	Date
	Satisfactory	Requires Attention			
Hood or inlet for a change of position or signs of damage					
Condition of the ductwork for leaks and the dampers for function					
Signs of damage (or partial disconnection) in areas of flexible ductwork					
Noise levels (increases may indicate turbulence, damage to mechanical bearings)					
Work area for signs of control failure (e.g. dust deposits, odours)					
Pressure gauges or airflow indicators					
Cleanliness of the filter or filter sock, filter bins not over filled					
Motorised filter shaking devices operational					
Correct water levels on wet scrubbers.					